

| SCHEMATIC LEGEND |                            |  |  |
|------------------|----------------------------|--|--|
|                  | Central Heating Pipework   |  |  |
|                  | Wiring                     |  |  |
| 1                | TRV                        |  |  |
| -4               | Lockshield Valve           |  |  |
| R                | 2 Port Zone Valve          |  |  |
| <b>₽</b> X       | Automatic By-pass Valve    |  |  |
| $\triangleright$ | Central Heating Circulator |  |  |
| * *              | Wiring Centre              |  |  |
| 0                | Cylinder Thermostat        |  |  |
|                  | Programmer                 |  |  |
| 21.0             | 4iE Thermostat             |  |  |



The world's **best-selling** floor heating brand™ WARMUP PLC, 702 & 704 Tudor Estate, Abbey Road, London, NW10 7UW Tel 0345 034 2288 Fax 0203 453 2299 support@warmup.com www.warmup.co.uk

| TITTLE<br>System Schematic<br>S Plan +  |       |          |  |  |
|---|-------|----------|--|--|
| DATE  | DRAWN | REVISION |  |  |
| 25.11.2016  | GW    | A        |  |  |
| PDF FILE  |       |          |  |  |
| Warmup - SS - S Plan + - 2016-11-25.pdf   |       |          |  |  |
| Any electrical works undertaken should be completed by a suitable<br>qualified competent electrician.   |       |          |  |  |
| Any interconnecting electrical components that form part of a hydronic system should be connected to a 3A power supply, with the whole system having a single point of isolation. |       |          |  |  |
| The Warmup word and associated logos are trade marks. © Warmup Pic. 2010 - Regd. TM Nos. 1257757, 4409926, 5265707. E & OE. Registered in England No. 2955213.                    |       |          |  |  |